

## Voltage Flicker Mitigation in Electric Arc Furnace using D-STATCOM

Deepthisree M, Ilango K, Kirthika Devi V S, Manjula G Nair

Departement of Electrical and Electronics Engineering, Amrita Vishwa Vidyapeetham, Amrita School of Engineering, Bengaluru, India

---

### Article Info

#### Article history:

Received May 10, 2014

Revised Aug 2, 2014

Accepted Aug 20, 2014

---

#### Keyword:

D-STATCOM-Distribution  
Static Synchronous  
Compensator  
EAF-Electric arc furnace  
Power Quality  
THD-Total harmonic distortion  
Voltage Flicker

---

### ABSTRACT

The major power quality issue of voltage flicker has resulted as a serious concern for the customers and heavy power companies. Voltage flicker is an impression of unsteadiness of visual sensation induced by a light source whose luminance fluctuates with time. This phenomenon is experienced when an Electric Arc Furnace (EAF) as load is connected to the power system. Flexible AC transmission devices (FACTS) devices were gradually utilized for voltage flicker reduction. In this paper the FACTS device of Distribution Static Synchronous Compensator (D-STATCOM) is used to serve the purpose of mitigating voltage flickering caused by electric arc furnace load, which is efficiently controlled by  $I\cos\phi$  control algorithm. The model of electric arc furnace is considered as a current source controlled by a non linear resistance, which had been simulated and performance was analyzed using MATLAB/SIMULINK Software.

Copyright © 2014 Institute of Advanced Engineering and Science.  
All rights reserved.

---

### Corresponding Author:

Ilango.K,  
Departement of Electrical and Electronics Engineering,  
Amrita Vishwa vidyapeetham University, Amrita School of Engineering,  
Kasavanahalli, Carmelaram (Post), Bengaluru, India- 560035  
Email: kilango2002@gmail.com

---

## 1. INTRODUCTION

The quality of power is a great concern for the heavy power companies and end users. There are many power quality issues such as sag, swell, harmonics, switching transients, interruptions, overvoltage, under voltage, voltage flicker, low power factor etc. The quality of power has an economic impact on consumers. Nonlinearity in the load causes harmonics which can cause drastic effects on the power supply and adversely affect the performance of other electrical equipments. Electric Arc Furnace is one such equipment, when connected to the grid system results in voltage fluctuations which lead to the power quality problem of voltage flicker, power factor reduction, and harmonic distortion in the electric grid. These problems reduces the electrical equipment efficiency. The problems caused by electric arc furnace can be solved by using many techniques, here D-STATCOM has been selected for mitigating voltage flicker and reduction of total harmonic distortion. Traditionally, SVC (Static Var Compensators) were used to solve the problem of voltage flicker, reactive powercompensation and power factor correction but it had few disadvantages that it generates lower order harmonics and takes longer response time compared to D-STATCOM. The D-STATCOM is an IGBT-based voltage source inverter which delivers faster response, power factor improvement and harmonic reduction, voltage sag mitigation since it uses highly advanced power switches [1]. D-STATCOM benefits in reducing the losses by maintaining high power factor at the load end, which eliminates voltage sags, swells and transients. If a D-STATCOM is well designed it serves as an advantageous investment for the power companies and can bring productive gains for the company as well as customers.

The control algorithm decides the functionality of D-STATCOM, various control strategies have been reported in literatures. The conventional algorithms took more computational time and were found to be slow in response which made it a necessity to go for new and faster control strategy for D-STATCOM [2]-[3]. In this paper  $I\cos\Phi$  control algorithm has been used for D-STATCOM to mitigate voltage flicker and power factor correction. This control algorithm is a very simple method which involves less computational time targeting to limit the voltage flicker at the source side. The detailed algorithm has been reported in [4] and its application to renewable energy source has been reported in [5]. The few modifications have been introduced with  $I\cos\Phi$  control algorithm which has been used for the control of D-STATCOM.

The power system model with electric arc furnace is shown in the Figure 1. The electric arc furnace load is connected to power system introducing a flicker. The D-STATCOM provides reactive power compensation, thereby stabilizing the power system voltage input and reducing the flickering. The modelling of electric arc furnace is described in Section 2. The control algorithm is explained in section 3. The simulation results and conclusion has been presented in section 4 and section 5 respectively.




Figure 1. Power system model with Electric Arc Furnace

## 2. MODELLING OF ELECTRIC ARC FURNACE

The most prevalent way today to reprocess steel from scrap is electric arc furnace. A wide variety of scrap can be melted in the arc furnace to produce steel with the help of electrodes and current. The electrodes are moved in and out of the furnace and thereby arcing occurs which melts the ore. Since electric arc furnace is a highly nonlinear load, the modelling of electric arc furnace and its equivalent electrical model is a difficult task. Many literatures have proposed different models of electric arc furnace such as harmonic voltage source model, time domain model, frequency model etc [6].

The modeling of electric arc furnace mainly depends on the parameters such as voltage, current and length determined by the position of the electrodes which is moved in and out of the electric arc furnace. EAF has both AC and DC models. The operation of EAF can be explained with various stages of arc processes such as the melting and refining. In the first stage the electrode is pushed in and out of the furnace by means of an external control stabilizing the arc. During this processes a momentary short circuit is experienced at the secondary side of the arc furnace transformer. High fluctuation in current is experienced when the arcing occurs. These high fluctuations in the current cause a flicker in the voltage.




Figure 2. V-I characteristics of arc

The electric arc furnace is modelled as a current controlled time varying nonlinear resistance using MATLAB [7]-[8]. MATLAB Embedded program takes in two inputs, electric arc furnace current and the derivative of electric arc furnace current to the function giving a time varying non linear resistance as output. The MATLAB embedded program function block is interconnected to the grid by a current controlled source. In real time electric arc furnace is modelled as a dynamic model. The voltage current characteristic is shown in Figure 1 [7]. Sinusoidal variation is assumed for the time varying nonlinear resistance.

$$R_{arc}(t) = R_{arc}(1 + m_d \sin(wt)) \quad (1)$$

Where:

$R_{arc}$  is the arc resistance

$m_d$  is the modulation coefficient

$w$  is the flicker frequency

$$R_s; \text{ for } 0 \leq |i| < i_g \text{ and } \frac{d|i(t)|}{dt} > 0 \quad (2)$$

$$R_{arc} = \frac{V_d + (V_g - V_d)e^{-\frac{(|i| < i_g)}{t_1}}}{|i|}; \quad (3)$$

$$\text{for } |i| \geq i_g \text{ and } \frac{d|i(t)|}{dt} > 0$$

$$R_{arc} = \frac{V_t + (V_g - V_t)e^{-\frac{|i|}{t_2}}}{(|i| + i_g)}; \text{ for } \frac{d|i(t)|}{dt} < 0 \quad (4)$$

Where,

$$V_g = 1.15 * V_d \quad (5)$$

$$i_g = \frac{V_g}{R_s} \quad (6)$$

$$V_t = \frac{(I_{max} + i_g)}{I_{max}} * V_d \quad (7)$$

$R_s$  : Slag resistance

$V_g$  : Arc voltage

$i_g$  : Arc current

$t_1$  : Time constant during melting process

$t_2$  : Time constant during arc extinction process




Figure 3. Simulink model of Single phase EAF model

### 3. CONTROL ALGORITHM

The D-STATCOM is connected at the point of common coupling and it is driven by  $I \cos \phi$  control algorithm. A simple method for achieving power factor correction and reduction of total harmonic distortion has prompted the proposal of  $I \cos \phi$  control algorithm [4]. The  $I \cos \phi$  is a less complicated and easy to implement algorithm. This algorithm is based on fundamental component of real part of load current. The current measured at the load side and voltage measured at the source side is given as input of controller. When load current passed through a second order low pass filter obtains fundamental load current with a phase shift of  $90^\circ$  using bi-quad filter. Unit amplitude source voltage is given to the 'detect fall negative block' which detects the zero crossing instant of the source voltage. Both the above mentioned current and voltage is moved as inputs to the sample and hold circuit. The magnitude of  $|I \cos \phi|$  is received as output from

the sample and hold circuit which is multiplied with the unit amplitude voltage to produce the desired source reference current at each phase. The desired source reference current is subtracted from the load current to obtain the reference compensation current. While generating compensation current, DC link voltage at the D-STATCOM side is balanced with help of pi controller which is added to the reference compensation current.

For a balanced source, the instantaneous voltages can be specified with a phase difference of  $120^\circ$ . Equations for phase 'a' are explained below.

$e_a$  =source voltage for phase a.

$i_{la}$  = load current for phase a.

$\phi_a$  = phase angle of fundamental current in phase a.

$i_{la1}, i_{lb1}, i_{lc1}$  = fundamental current amplitude for phase a,b,c.

$U_a$  = unit amplitude of source voltage of phase a.

$i_a$  = magnitude of desired current.

$i_{da}$  =desired current

$i_{ca}$  =compensation current

$e_{dc}$  = dc link voltage at D-STATCOM terminal

$e_{dcref}$  =dc reference voltage

$$e_a = E_m \sin \omega t \tag{8}$$

$$|R_e(i_{la1})| = |i_{la}| * \cos \phi_a \tag{9}$$

$$U_a = 1. \sin \omega t \tag{10}$$

$$|i_a| = \frac{|R_e(i_{la1})| + |R_e(i_{lb1})| + |R_e(i_{lc1})|}{3} \tag{11}$$

$$i_{da} = |i_a| * \sin \omega t \tag{12}$$

$$i_{ca} = i_{la} - i_{da} \tag{13}$$

Error at the nth sampling instant

$$error(n) = e_{dcref} - e_{dc}(n) \tag{14}$$

Error is fed to PI controller to generate  $i_{caerr}$ .

$$i_{caerr}(n) = \{ i_{caerr}(n - 1) + k_p (error(n) - error(n - 1)) + k_i (error(n)) \} \tag{15}$$

$i_{comp}$  Current is passed to the hysteresis controller to generate pulses for D-STATCOM.

$$i_{comp} = i_{ca} + i_{caerr} \tag{16}$$




Figure 4. Simulink model of three phase system supplying Electric Arc Furnace load with D-STATCOM

The electric arc furnace was designed to 30 MW which is connected to the three phase electric grid. The D-STATCOM and its control algorithm were modeled and developed using MATLAB which was presented in Figure 4. The system was designed with simulation parameters shown in Table 1.

Table 1. Simulation Parameters

$V_{source}$	500V
$f$	50Hz
$Z_s$	$0.000528+j0.00468\Omega$
$Z_t$	$0.0003366+j0.00322\Omega$
$R_s$	0.05 $\Omega$
$V_g$	350.75V
$I_{max}$	100KA
$t_1$	0.01sec
$t_2$	0.01sec
DC link voltage	680V
DC link capacitor	500000 $\mu$ f
Coupling Inductance	8mH

#### 4. SIMULATION RESULTS

The described system was simulated and the results have been analyzed. The Figure 5 depicts the arc furnace load voltage waveform at source side. From Figure 5, it was clear that, flickering has been experienced when the electric arc furnace was connected at the load side. The percentage of flickering in the voltage without connecting D-STATCOM was found to be 8.8%.

The Figure 6 shows the arc resistance waveform of arc furnace. Figure 7 depicts the arc current waveform which has the average magnitude of 60kA.

The Figure 8 shows the source voltage waveform when the D-STATCOM was connected to the network at the point of common coupling. From Figure 8, it is clear that the source voltage wave is a pure sinusoidal without flickering effect.

The arc furnace load current THD analysis has been shown in Figure 9 which contains 20.91% of harmonics before compensation using D-STATCOM. From Figure 10, it can be observed that the THD analysis of arc furnace load current after compensation has reduced to 1.69%.

After compensation the source voltage and source current waveform has been depicted in Figure 11 which shows that the voltage and current were in-phase with each other. This was evident for power factor correction using D-STATCOM.

The arc furnace source voltage THD analysis has been carried out and shown in Figure 12, which contains harmonics of 33.02%. From Figure 13, it can be seen that the source voltage THD of arc furnace hafter compeas been reduced to 0.02% from 33.02%.




Figure 5. Arc voltage before compensation




Figure 6. Arc resistance




Figure 7. Arc current




Figure 8. Source voltage after compensation




Figure 9. THD of current before compensation




Figure 10. THD of current after compensation




Figure 11. Source voltage and current




Figure 12. THD of voltage before compensation




Figure 13. THD of voltage after compensation

## 5. CONCLUSION

This paper presents the electric arc furnace model in time domain analysis which was modelled using matlab/simulink and the major power quality issues caused by electric furnace has been studied. The D-STATCOM was used as voltage source inverter which mitigates the power quality issue of voltage flicker created by electric arc furnace. The D-STATCOM control was achieved using Icos $\phi$  control algorithm which has been implemented with few modifications to make the controller more effective. From the simulation results, voltage flicker and THD on current were reduced and the power factor correction for arc furnace load was obtained closer to unity.

## REFERENCES

- [1] Ambar Nath Banerji, Sujit K Biswas, Bhim Singh. D-STATCOM Application of voltage sag caused by dynamic loads in autonomous systems. *International Journal of Power Electronics and Drive System (IJPEDS)*. 2012; 2(2): 232-240.
- [2] Ambar Nath Banerji, Sujit K Biswas, Bhim Singh. D-STATCOM control algorithms: a review. *International Journal of Power Electronics and Drive System (IJPEDS)*. 2012; 2(3): 285-296.
- [3] HL Jou. Performance comparisons of the three-phase active power filter algorithms. *IEEE Proc-gener. Transm. distrib.*, 1995; 142(6): 646-652.
- [4] G Bhuvaneshwari, Manjula G Nair. Design, simulation and analog circuit implementation of a three phase shunt active filter using the Icos $\phi$  algorithm. *IEEE transactions on power delivery*. 2008; 23(2): 1222-1235.
- [5] Ilango K, Bhargava A, Trivikram A, Kavya PS, Mounika G, Manjula G Nair. Power quality improvement using STATCOM with renewable energy sources. *IICPE*. IEEE. 2012: 1-6.
- [6] S Pushpavalli, A Cordelia Sumathy. Harmonic reduction of arc furnaces using D-STATCOM. *IOSR JEN*. 2013; 3(4): 7-14.
- [7] K Anuradha, BP Muni, AD Raj Kumar. Modelling of electric arc furnace and control algorithms for voltage flicker mitigation using D-STATCOM. *IPERC IEEE*. 2009: 1123 – 1129.
- [8] Tongxin Zheng, Elham B Makram. An adaptive model arc furnace model. *IEEE transactions on power delivery*. 2000; 15(3): 931-939.

## BIOGRAPHIES OF AUTHORS



Deepthisree M obtained her B. Tech in Electrical and Electronics Engineering from kannur University, Kerala. Currently she is doing her M.Tech Power Electronics in Amrita School of Engineering, Amrita Vishwa Vidyapeetham (University), Bengaluru campus



Ilango. K obtained his B.E. degree in Electrical and Electronics from Madurai Kamaraj University, Tamil Nadu and M.E .in Power Systems from P.S.G. College of Technology, Anna University. He is currently pursuing Ph.D. in Amrita School of Engineering, Amrita Vishwa Vidyapeetham (University), Bengaluru campus. He has been teaching for seven years and presently, he is Assistant Professor (Sr.Gr), Amrita School of Engineering, Amrita Vishwa Vidyapeetham University. His areas of interest are Power quality, Renewable energy source, and Electrical drives.



Kirthika Devi V S obtained his B.E. degree in Electrical and Electronics from Bharathiyar University, Tamil Nadu and M.E .in Applied Electronics from, Anna University. She is currently pursuing Ph.D. in VTU. She has been teaching more than seven years and presently, she is Assistant Professor (Sr.Gr), Amrita School of Engineering, Amrita Vishwa Vidyapeetham University. Her areas of interest are Power Electronics applications in Renewable Energy Sources.



Dr. Manjula G.Nair obtained her Master's degree in Power systems from University of Calicut, Kerala and Ph.D. degree from IIT-Delhi. Since 1995, she has been with the Department of Electrical Engineering, Amrita School of Engineering, Amrita Vishwa Vidyapeetham (University), India. She is currently Professor of the Department of Electrical Engineering, Amrita School of Engineering, Amritapuri campus, kerala India. Her areas of interest are FACTS controllers, Fuzzy and ANN based control of Power Systems, Power Quality, Hybrid and Active Filters, Renewable Energy Systems.